



FORM B 13.3

## FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOAMC/2021/00012386  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOAMC/2021/00012386/R1

Date: 24/01/2024

Building Occupancy/Category: Educational (non-residential)

To,

Prakash high secondary school  
PRAKASH HIGHER SECONDARY SCHOOL OPP.SANDESH PRESS, B/H AMALTHAS BUNGLOWS BODAKDEV AHMEDABAD  
Ahmedabad MC 380054  
Fire Region: Ahmedabad MC  
Mobile No: 9825025446 Email ID: phss1971@yahoo.co.in

This has reference to your Application No. **2024/00044696** dated 12/01/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise **PRAKASH HIGHER SECONDARY SCHOOL** (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: AHMEDABAD
5. Name of Block(s): 1

The building/premise was inspected on **24/01/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **24/01/2024**
2. Six monthly inspection was done on **24/01/2024**

The Fire Safety Certificate is renewed for a period of **two (2) years** upto **24/01/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



### Digitally Verified

Digitally verified by: Jigarkumar Pankajbhai Patel  
Fire Safety Officer - General (FSO-G)  
2021/000654


Date: 24/01/2024  
Time: 11:40 AM



FSCA/O/CFOAMC/2021/00012386/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujaratfiresafetycop.in](http://www.gujaratfiresafetycop.in).

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.



*[Handwritten Signature]*  
Principal  
Prakash Higher Sec. School  
Ahmedabad